



NOTES:

1. 4 1/2" PUMPER NOZZLE TO FACE STREET
2. HYDRANT NOT TO BE SET ON STREET SIDE OF WATER MAIN
3. VALVE BOX TO BE ADJUSTED TO GRADE
4. CONCRETE COLLAR AROUND VALVE BOX IF NOT IN PAVED AREA
5. GRAVEL TO BE PLACED AROUND HYDRANT DRAIN, MINIMUM DIMENSIONS 20" x 20" x 20"

TYPICAL FIRE HYDRANT INSTALLATION

**CHEROKEE COUNTY
WATER & SEWERAGE
AUTHORITY**

**TYPICAL
FIRE HYDRANT
INSTALLATION
CONSTRUCTION STANDARD**

DATE: FEB. '03

APPROVED:

STANDARD
NO.

W702