



Cleanout Detail
(By Builder)

- Notes:
- 1.) Cleanouts in driveways, walkways, paved areas shall be brass plugs or traffic rated cast iron boxes w/covers.
 - 2.) No trees, shrubs, landscaping and/or structures shall be within 5' of the cleanout.

CHEROKEE COUNTY WATER & SEWERAGE AUTHORITY	CLEANOUT DETAIL CONSTRUCTION STANDARD	DATE:	MAR. '04	STANDARD NO. S713
			Rev. '07	
		APPROVED:		