



PROFILE VIEW

PIPE DIA.	L	B
6"	4'	1'
8"	4'	1'
10"	4'	1'
12"	4'	1'
16"	4'	2'

NOTE:

CONCRETE COLLAR WIDTH EQUALS THE WIDTH OF THE TRENCH PLUS FOUR FEET (TWO FEET ON EACH SIDE OF THE TRENCH).

CONCRETE THRUST COLLAR

CHEROKEE COUNTY WATER & SEWERAGE AUTHORITY	CONCRETE THRUST COLLAR CONSTRUCTION STANDARD	DATE:	FEB. '03	STANDARD NO. W717
		APPROVED:		