



**MINIMUM P.V.C. PIPE
BEDDING DETAIL**

NOT TO SCALE

NOTE: IF PVC SANITARY SEWER LINE IS CONSTRUCTED IN 100 YEAR FLOOD PLAIN OR BELOW GROUNDWATER TABLE, COMPACTED CLASS 1 MATERIAL IS REQUIRED TO THE TOP OF THE PIPE.

**CHEROKEE COUNTY
WATER & SEWERAGE
AUTHORITY**

**MINIMUM
P.V.C. PIPE
BEDDING DETAIL**
CONSTRUCTION STANDARD

DATE: FEB. '03

APPROVED:

STANDARD
NO.
S720