



NOTES:

- 1. FOR 12" AND SMALLER FORCE MAINS, A 6' MIN. DIA. MANHOLE IS REQUIRED.
- 2. FOR FORCE MAINS LARGER THAN 12", AN 8' MIN. DIA. MANHOLE IS REQUIRED.

**FORCE MAIN CONNECTION
TO EXISTING MANHOLE**

CHEROKEE COUNTY WATER & SEWERAGE AUTHORITY	FORCE MAIN CONNECTION TO MANHOLE CONSTRUCTION STANDARD	DATE: FEB. '03	STANDARD NO. S722
		APPROVED: _____	