



MINIMUM SIZE: 1,500 GALLONS

NOTE:
 SIZE AND DIMENSIONS OF COMBINATION SAND/OIL TRAP AND PIPING
 DEPENDENT ON QUANTITY OF FLOW. DESIGN ENGINEER
 SHALL SUBMIT CALCULATIONS TO SUPPORT DESIGN SIZE.

CHEROKEE COUNTY WATER & SEWERAGE AUTHORITY	TYPICAL COMBINATION SAND/OIL TRAP CONSTRUCTION STANDARD	DATE:	FEB. '03	STANDARD NO. S726
		APPROVED:		